



- DESIGN: MODULAR
- DEGREE OF PROTECTION: IP66
- YEARS OF WARRANTY: 2
- UV RESISTANCE: YES
- READY TO CONNECT: YES
- WEIGHT: 21.19 KG



The connection panel from the Polish manufacturer EMITER provides protection against the effects of indirect discharges on the direct current side. It is designed for use in grounded and isolated photovoltaic installations. Due to the high degree of IP protection, outdoor installation is possible. The design of the switchgear is intended for surface mounting. Depending on the equipment, switchboards can perform various functions.

### BASIC PARAMETERS DC SIDE

Number of inputs   PV string outputs	11   11
Quantity   Type of DC surge arrester   Type	11   Noark   T2
Connection type	Array MC4 Stäubli

### ELECTRICAL AND MECHANICAL PARAMETERS OF THE HOUSING

Model	GW-IP66
The number of modules	54
Dimensions of housing without chokes and MC4 (Length Width Height)	210.00   495.00   500.00
Design in accordance with	EN 61439-1, EN 61439-2, EN62208, EN 60670-1, IEC 60670-24
Level of security	IP66
Protection class	II
Rated insulation voltage $U_i$	1000 V in accordance with the standard EN 62208 both for alternating current (AC), as well as direct (DC)
The incandescent rod test	960°C
Impact resistance	IK10
UV resistance	UV resistance (EN 62208)
Operating Temperature °C	-25 +60 °C

Material

Glass fibre reinforced polyester

### DC surge arrester used (SPD)

Manufacturer / Model

Noark Ex9UEP 20(R) 3P 1000

Made in accordance with

EN 50539-11

Surge protection

T2 (klasa II, C, T2)

Making the insert

MOV (Warystor)

Rated operational voltage  $U_n$

1000 V

Maximum continuous operating voltage  $U_{CPV} + \rightarrow PE, - \rightarrow PE + \leftrightarrow -$

1000 V

Maximum open circuit voltage UOC max

905 V

Frequency

DC

Nominal discharge current  $I_n (8/20 \mu s)$

20 kA

Maximum discharge current  $I_{max} (8/20 \mu s)$

40 kA

Total discharge current  $I_{total} (8/20 \mu s)$

40 kA

Voltage protection level  $U_p$  by  $I_n + \rightarrow PE, - \rightarrow PE + \leftrightarrow -$

3.8 kV

Leakage current  $I_{PE}$  by  $U_{REF}$  DC

< 50  $\mu A$

Leakage current  $I_{PE}$  by  $U_{REF}$  AC

< 1 mA

Maximum short-circuit current  $I_{SCPV}$

1000 As

